

A

B

C

D

E

F

A

B

C

D

E

F

FULLY SPRINKLERED

CONTRACTOR SHALL INSTALL NEW FAUCETS WITH CHECK VALVES IN ALL HOUSEKEEPING AID CLOSETS (HAC'S), TO ENSURE NO COLD WATER BACK FEED INTO THE CHEMICAL INJECTION SYSTEM. WORK MAY REQUIRE MINOR DEMOLITION AND REPAIR TO ACCESS VALVES IN WALLS/CEILINGS.

HAC'S Room #
5A120
5A153
5B100
5C115
5D102

REMOVE UNUSED/UNDERUSED SINKS, SHOWERS AND TOILETS IN LOCATIONS NOTED ON PLANS. PIPING WILL NEED TO BE CUT BACK AND CAPPED AT MAIN AND ALL "DEAD LEG" PIPING REMOVED.

FIXTURE REMOVAL Room #
5C119

** Deleted from Project

BLDG #1 - FIFTH FLOOR
SCALE: 1/16" = 1'-0"



PLOTTING NOTES:

1. FULL SIZE V.A. 'E' SHEET (AS INDICATED)
2. HALF SIZE V.A. 'D' SHEET (1/2 THE INDICATED SCALE)
3. LETTER SIZE (NOT SCALE)

GENERAL NOTES:

1. SCALED DIMENSIONS + ARCHITECTURAL FEATURES MAY NOT BE CORRECT.
2. CONTRACTORS + A/E'S ARE RESPONSIBLE TO FIELD VERIFY ALL DIMENSIONS WITHIN THE PROJECT AREA.

DEPARTMENT OF VETERANS AFFAIRS
MEDICAL CENTER
1055 Clermont Street
Denver, Colorado, 80220

Drawing Title

FIFTH FLOOR
HOUSEKEEPING AID CLOSETS LOC

Approved Project Director

Project Title

Correct Hot Water System
Deficiencies Phase 1

Location
DENVER VA MEDICAL CENTER

Date
27 DEC, 2013

Checked
T. VIGIL

Drawn
D. ZETHREN

Project Number

554-14-804

Building Number

BUILDING 1

Drawing Number

A106Rev

Dep. 7 of 26

Office of
Construction
and Facilities
Management



C:\Users\vhachkov\OneDrive\LocalTemp\appdata\LocalTemp\11172_007 A106 Bldg 1 - 5th Floor w HACs.dwg 1-29-14 02:27:31 PM VHAACHKOV\N